CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-1339:109 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: Optex Morse, Inc., 1845 W 205th Street, Torrance, CA 90501

Contact: *Eric J. Mott (310) 533-1500

DESIGN: Models Genesys 824 and G-824 ALPHA fire warning systems. Refer to listee's data sheet

for additional detailed product description and operational considerations. This listing

includes the following components:

G-824/-824 Alpha Control Unit G-KP/-824 Alpha Keypad G-FM/-FM II Fire Module G-FX **Expansion Module**

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire warning control units for use with separately listed compatible initiating and

indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive threepulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

NOTE: Burglary and other non-fire functions were not examined. Refer to listee's

data sheet for compatible non-fire devices.

*Rev. 07-16-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JULY 24, 2002 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager